

Institut für Energie- und
Umwelttechnik e.V. (IUTA)
Air Quality & Filtration
Bliersheimer Straße 58 - 60
47229 Duisburg
Germany



- IUTA-CERTIFICATE -
Validation of compressed air filters
according to ISO 12500-3:2009^{1) 2)}

(Filters for compressed air – Test methods – Particulates)

- 1) According to the state of the art in particle measurement technology via online optical aerosol spectrometry particle sizes < 0.14 µm cannot be detected under pressure.
- 2) Particle size range: (0.19 – 2.74) µm

Customer: Dropout Technology Limited, Unit 22 Oakham Enterprise Park, Ashwell Road
Oakham, Rutland, LE 15 7NZ , UK

Tested product: DO900S

IUTA test report: Data report 05 March 2015

Tested cartridge: Single measurement of three cartridges model DO900S

Test parameter:									
Inlet pressure		7 bar (e) [8 bar (a)]							
Air flow		48 Nm ³ /h = 100 % nominal flow rate							
Flow direction		from inside to outside							
Test aerosol		DEHS							
Particle size range		(0.19 – 2.74) µm							
Aerosol Spectrometer		PCS 2100 (Palas GmbH)							
Test results:									
Particle-size range [µm]		lower	0.19	0.24	0.36	0.52	0.81	1.15	1.78
		upper	0.24	0.36	0.52	0.81	1.15	1.78	2.74
Average efficiency* [%]			90.11	91.51	93.71	96.45	99	99.81	100

Remark: The product was tested under the designation DO900S

* Averages were calculated from the data shown in the test report (mean values of 3 tests in filter housing model DO900S).

Duisburg, 12 March 2015

Managing Director

A handwritten signature in blue ink, appearing to read "A. Haas". It is positioned above a horizontal line.

Department Head

A handwritten signature in blue ink, appearing to read "M. J. Müller". It is positioned above a horizontal line.